



T&M Request

Form 1069 v2018.1

Date: 5-9-24 Requested by: Rob Ashton Company: Precision Pipeline

Oracle Project # 109800102 Task: _____ Maximo # _____

OC: WA Site Address: 24 Bowers St

Project Type:

- System Improvement Main Service
- Public Improvement Main Service
- New Business Main Service Meter
- Blanket Main Service Retire
- BSCI Main Service
- Modernization Main Service

Brief Description of Request:

Responded to main leak. Found out affected main is slotted to be replaced this year on V-X-1763.

Contributing Factors:

Out of Scope (Describe):

Change in Scope (Describe):

Other (Describe):

Estimated Charge Resulting from Request (Labor Hours and Tooling):

3013525 - 3 person construction crew - 3hrs

Did T&M Result from Change in Construction? Yes No

Did T&M Create a Change in Construction? Yes No

Approved By J. Wilhelm (Operations Supervisor) Date 5/9/24

Approved By _____ (Project Engineer) Date _____