



T&M Request

Form 1069 v2018.1

Date: 5-29-24 Requested by: Anthony Delawder Company: Precision Pipeline

Oracle Project # V-360 Task: _____ Maximo # 112339755 112339755

OC: Dayton West Site Address: 4800 N. Dixie Drive

Project Type: (Main is on ottello Drive) CP2445

- System Improvement Main Service
- Public Improvement Main Service
- New Business Main Service Meter
- Blanket Main Service Retire
- BSCI Main Service
- Modernization Main Service

Brief Description of Request:

Found leaks on 4" steel low pressure main via the vic truck.
Fixed leaks the best we could with out further damaging the rotted main.
The main does have cracks in it & is fizzing.

Contributing Factors:

Out of Scope (Describe):
Existing 4" steel main is in horrible condition, & leaking.

Change in Scope (Describe):

Other (Describe):

Estimated Charge Resulting from Request (Labor Hours and Tooling):

3 hours - 3 man crew

- Did T&M Result from Change in Construction? Yes No
- Did T&M Create a Change In Construction? Yes No

Delawder work date
5/29/2024
CP 2445
V-360
PK 66
SAP 112339755

Leak on existing main -
Repaired Leak

3 HRS
3 MAN
3013525

Approved By Scott Emrick (Operations Supervisor) Date 6.5.24

Approved By _____ (Project Engineer) Date _____