



T&M Request

Form 1069 v2018.1

Date: 3/22/24 Requested by: Rob Ashton Company: PPL

Oracle Project # 111441259 Task: _____ Maximo # _____

OC: WA Site Address: 254 E Court St

Project Type:

- System Improvement Main Service
- Public Improvement Main Service
- New Business Main Service Meter
- Blanket Main Service Retire
- BSCI Main Service
- Modernization Main Service

Brief Description of Request:

Crew dispatched to a service renewal - leak. Crew dug up curb valve and soaped out. Pressure tested, soaped, and CG'd no leak found. Crew backfilled, sand padded, and reset pavers.

Contributing Factors:

Out of Scope (Describe):

Change in Scope (Describe):

Other (Describe):

Estimated Charge Resulting from Request (Labor Hours and Tooling):

3013525 - 3 person construction crew - 9.5 hrs

Did T&M Result from Change in Construction? Yes No

Did T&M Create a Change in Construction? Yes No

Approved By J Wilhelm (Operations Supervisor) Date _____

Approved By _____ (Project Engineer) Date _____